

1109241

CONTACTOR 3P+1NO 9A AC3

Date: 12-11-2024

ORIGINAL
OSP
 SPARE PARTS



TYPE BG09
 400V - 415V - 500V - 600V - 690V
 2.2 4 4.3 5 5

| | | | | | | | | |
|---|-----|-----|-----|-----|-----|-----|-----|-----|
| 1 | 1.2 | 1.7 | 2.2 | 2.8 | 3.4 | 4.0 | 4.7 | 5.5 |
| 1 | 1.2 | 1.7 | 2.2 | 2.8 | 3.4 | 4.0 | 4.7 | 5.5 |

75°C CU WIRE ONLY 2.4 AWG 18 TO 12
 SUITABLE FOR USE ON A CIRCUIT BREAKER
 300V RMS SYM. PASSES 200 MAX. CLASS J
 USE TIGHTENING TORQUE 9 LB IN
 ALUK CONTACT 1800 LB IN

LOWELECTRICALS P.A. - Via Don E. Mazzi 12 - 21020 COZZE (Bergamo) ITALY

